



NOTES:
 1. LUBRICATE CONTACT SURFACES
 2. FOR CORRECT CONTACT PRESSURE ON CLIP, ADJUST BLADES SO THEY ARE .013 ± .004 WIDER IN THE CLOSED POSITION THAN IN THE OPEN POSITION. THIS DIM. MUST BE MEASURED ON THE OUTSIDE OF THE BLADES, ABOVE THE CONTACT POINTS.

					16	-
					15	-
					14	-
					13	-
	4	4	4	-	12	DRIVE SCREW
	12	12	12	-	11	MACHINE BOLT 1/2" X 1 1/4" LW
	1	1	1	MP251800X	10	NAMEPLATE
	3	-	-	-	9	INSULATOR (TR208)
	-	3	-	-	8	INSULATOR (TR205)
	-	-	3	-	7	INSULATOR (TR202)
	1	-	-	A009636	6	CURRENT CARRYING PARTS 23 KV
	-	1	-	A009635	5	CURRENT CARRYING PARTS 15 KV
	-	-	1	A009634	4	CURRENT CARRYING PARTS 7.5 KV
	1	-	-	087521SXG GALV	3	MOUNTING BASE 23 KV
	-	1	-	087520SXG GALV	2	MOUNTING BASE 15 KV
	-	-	1	087519SXG GALV	1	MOUNTING BASE 7.5 KV

QUANTITY	PART	MATERIAL	ITEM	DESCRIPTION
TEL:				
CUSTOMER P.O.#				
SERIAL NUMBER:				
REVISIONS		DATE	BY	CHK
DRAWN BY CAL. BY BLK. DESG. BY WJS		10-18-02	WJS	A
DRAWING #		BY	DATE	
D84002-2		MJR	10-18-02	
SHEET 1 OF 1		APP'D BY	DATE	
		WJS	10-18-02	

BT2T-7, 15, 23-12/6013
 HOOKSTICK SWITCH
 TURNER ELECTRIC CORPORATION
 FAIRVIEW HEIGHTS, IL., USA