



NOTES:  
 1. FOR CORRECT CONTACT PRESSURE ON CLIP ADJUST BLADES SO THEY ARE .013 ± .004 WIDER IN THE CLOSED POSITION THAN IN THE OPEN POSITION. THIS DIM. MUST BE MEASURED ON THE OUTSIDE OF THE BLADES, ABOVE CONTACT POINTS.  
 2. LUBRICATE CONTACT SURFACES PER SPEC. TT39 SEC. 1 PARA. A1

QUANTITY	PART	MATERIAL	ITEM	DESCRIPTION
4	-	-	7	-
1	MP251BODY	ALUM	6	DRIVE SCREW
8	-	GALV	5	NAMEPLATE
2	SEE ORDER	-	4	MACHINE BOLT 1/2"-13 X 1" N, LW
1	A009660	-	3	INSULATOR (TR 214)
1	071018SXG	GALV	2	CURRENT CARRYING ASSY BT2-46KV-600A
			1	SWITCH BASE (2" X 3" MTG)
TO:				
CUSTOMER P. O. #				
SERIAL NUMBER:				
REVISIONS	DATE	BY	MARK	46 KV
REDRAWN TO CAD: EEN 3276	10-4-02	MJR	A	600 AMP
DRAWING #				BT2-46-06/6008
SK871019				CONTROL MECHANISM
SHEET 1 OF 1				TURNER ELECTRIC CORPORATION FAIRVIEW HEIGHTS, IL., USA