



NOTES:  
1. FOR CORRECT CONTACT PRESSURE ON CLIP  
ADJUST BLADES SO THEY ARE .013 ± .004 WIDER  
IN THE CLOSED POSITION THAN IN THE OPEN  
POSITION. THIS DIM. MUST BE MEASURED ON THE  
OUTSIDE OF THE BLADES, ABOVE CONTACT POINTS  
2. LUBRICATE CONTACT SURFACES PER SPEC.  
TT39 SEC. 1 PARA. A1

7	-	-	-	-	-
4	-	-	-	6	DRIVE SCREW
1	MP251800X	ALUM	5	NAMEPLATE	
-	-	GALV	4	MACHINE BOLT 1/2"-13 X 1" N,L,W	
2	SEE ORDER	-	3	INSULATOR (TR 214)	
1	A009852	-	2	CURRENT CARRYING ASSY BT2-48KV-1200A	
1	0710185XG	GALV	1	SWITCH BASE (2" X 38" MTG)	
QUANTITY	PART	MATERIAL	ITEM	DESCRIPTION	
TO:					
CUSTOMER P.O.#					
SERIAL NUMBER:					
REVISIONS		DATE	BY	MARK	
REDRAWN TO CAD; EON 3276		10-4-02	MLR	A	
DRAWING #		BY	DATE	48 KV	
SK871020		MSD	10-19-87	1200 AMP	
SHEET 1 OF 1		APP'D BY	DATE	BT2-46-12/6009	
		WSD	11-13-02	CONTROL MECHANISM	
				TURNER ELECTRIC CORPORATION	
				FAIRVIEW HEIGHTS, IL., USA	