



MIDDLE PHASE SHOWN
 NOTE: CONVERTING EXIST. WOOD POLE MFG TO "LUDY" STEEL POLE MFG
 REQUIRES PRT#AA11391 (INCLUDES PRT# 8, 9, 10, 25, 27, 28)

| QTY | PART | MATERIAL | ITEM | DESCRIPTION |
|-----|----------------|----------|------|--|
| 6 | | GALV | 32 | MACHINE BOLT 1/2"-13 X 1 1/2" N.L.M FN (GRD 5) |
| 18 | | GALV | 31 | MACHINE BOLT 5/8"-11 X 1 1/2" B.U.L.M |
| 8 | | GALV | 30 | MACHINE BOLT 1/2"-13 X 1 1/2" L.M |
| 8 | | GALV | 28 | CHARANGE BOLT 1/2"-13 X 1 1/2" N.L.M |
| 3 | 001130BKT | GALV | 28 | BOTTOM FRAME LG POLE MFG PLATE |
| 3 | 00130BKT | GALV | 27 | TOP FRAME LG POLE MFG PLATE |
| 1 | 0001300 | GALV | 28 | 2" IPS PIPE SCH 40 # 8' - 6" |
| 4 | 002710BKT | ALUM | 25 | PIPE GLIDE MFG BKT. |
| - | | | 24 | TEED RUPTER (OPTIONAL) |
| 6 | M252002 | | 23 | 138 KV INSULATOR (10288-94) |
| 3 | 000P0005105404 | | 22 | JAM PEDESTAL & SPACER |
| 3 | A825 | | 21 | LN JAM ASSY 1.8KV 1200AMP |
| 3 | A824 | COPPER | 20 | LN BLADE ASSY 1.8KV 1200AMP (2.5') |
| - | A824 | | 19 | LN JAM ASSY 1.8KV 1200AMP |
| - | A825 | COPPER | 18 | LN BLADE ASSY 1.8KV 1200AMP (2.5') |
| 1 | 0001300 | GALV | 17 | 2" IPS PIPE SCH. 40 # 10' - 0" |
| 3 | 0001300 | GALV | 16 | 2" IPS PIPE SCH. 40 # 21' - 0" |
| 3 | A825 | GALV | 15 | PIPE COUPLING |
| 4 | A825B | GALV | 14 | P-GLIDE ASSY (3880) |
| 1 | A826B | ALUM | 13 | LOCKING PLATE ASSY |
| 1 | A826S | GALV | 12 | OPER ASSY |
| 1 | 004230BKT | ALUM | 11 | OPER BKT |
| 2 | 0014444 | ALUM | 10 | PHASE GUIDE |
| 1 | A827 | | 9 | 1-BEARING ASSY |
| 3 | 002500BKT | ALUM | 8 | 1-BEARING MFG BKT |
| 3 | A825S | GALV | 7 | 7" LEVER ASSY |
| 3 | 0001300 | GALV | 6 | 1" IPS PIPE SCH. 40 # 8" |
| 6 | A825S | GALV | 5 | 1" LEVER ASSY |
| 3 | A821 | ALUM | 4 | PIVOT ASSY (4851) |
| 1 | A8277 | GALV | 3 | PIPE TO PIPE U-JOINT ASSY |
| 3 | 0017000 | GALV | 2 | INSULATOR PEDESTAL |
| 3 | A822 | GALV | 1 | 100-138 FRAME ASSY/W/ FRAME |

REVISIONS

| REV | DATE | BY | MARK | DESCRIPTION |
|-----|------|----|------|-------------|
| | | | | |

DRAWING # **SK980618**
 SHEET 1 OF 1

BY: JEF
 DATE: 7-27-09

APP'D BY: [Signature]
 DATE: [Blank]

CUSTOMER P.O.# [Blank] SERIAL NUMBER: [Blank]

138 KV
 10013012/1236 SIDE BREAK SWITCH
 ON S.P. LDB W/Ø 2-1/2" BLADES

TURNER ELECTRIC CORPORATION
 FAIRVIEW HEIGHTS, IL., USA

